

## CERTIFICATION

June 11, 2004

To whom it may concern:

This letter is to certify that Koester American Corporation meets and or exceeds the following test requirements for their VAP I<sup>®</sup> Systems:

Water Vapor Transmission:	ASTM E96-0.20 grains/hr./ft <sup>2</sup> .
Alkali Resistance:	ASTM-D 1308-pass, no effect when tested for a period of 14 days.
Adhesion Strength:	ASTM-D -4541-635 psi (100% cohesive failure of substrate)
Anti Microbial Agent:	Standard VAP I formulation type.
Single Responsibility:	Standard Koester comprehensive Warranty up to 15 years (if required.) Single source responsibility for manufacturing material performance, testing provided. (Installation by trained, approved applicators.)
Extended Warranty:	Koester American Corp. warrants against failure of membrane materials due to moisture vapor and alkalinity for a period of 10 years. In case of failure remove defective materials, replace membrane and floor coverings to satisfaction of and at no cost to owner.

- 1.) Underwriters Insurance: manufacture will provide a warranty backed by \$5,000,000 per occurrence Product Liability Insurance which co-insures the Owner, Architect and Contractor.
  - a.) Proof of Insurance coverage available on request.
  - b.) History of liability insurance for a minimum of 5 years available.

Signed,

Harald Muench, President